

Prototype testing of 400 kV 2C D/C Transmission Line Tower Type “TD60/DE”. for  
M/s HVEN, ARMENIA.

**M/s FARA GOSTAR BISTOON CO., Iran** have referred to **CSIR-Structural Engineering Research Centre**, Chennai, for testing of 400 kV 2C D/C Transmission Line Tower Type “TD60/DE”. The tower is tested for **HVEN, ARMENIA**. The Double Circuit tower is 19 m wide at base and 72.5 m height. The tower was tested for 8 different load cases as per IEC: 60652 2002-06 specifications.

