

Prototype testing of 400 kV double circuit “NFD0 (0°)” type Tower for Madhya Pradesh Power Transmission Co. Ltd, Jabalpur

**M/S ARCON POWERTRANS PVT. LTD., Nagpur**, have referred to **CSIR-Structural Engineering Research Centre, Chennai**, for testing of 400 kV double circuit “NFD0 (0°)” type Tower. The tower is tested for **Madhya Pradesh Power Transmission Co. Ltd, Jabalpur** for 400 kV D/c Transmission line. The tower is 13.474 m wide at base and 57.21 m height. The tower was tested for 7 different loading cases as per IS: 802 Part III specifications.

