

Prototype testing of 400 kV Single Circuit HAT4 (30° - 60°) / Terminal MKD 'C' type tower for Millennium Challenge Account, Malawi.

M/s Kalpataru Power Transmission Ltd., Gandhi Nagar, Gujarat, India have referred to **CSIR-Structural Engineering Research Centre, Chennai**, for testing of 400 kV Single Circuit HAT4 (30° - 60°) / Terminal MKD 'C' Tower Type. The tower is tested for **Millennium Challenge Account, Malawi**. The tower is 16.544 m wide at base and 44.30 m height. The tower was tested for 6 different load cases as per IEC 60652 Standard.

