

Prototype testing of 500 kV S/C “AP” type tower tested for Convocatoria UPME 01- 2013 Ingenieria De Detalle Y Estudios Ambientales (Fase II).

M/s Karamtara Engineering. Pvt. Ltd., India India have referred to CSIR-Structural Engineering Research Centre, Chennai, for testing of 500 kV S/C “AP” type tower. The tower is tested for Convocatoria UPME 01- 2013 Ingenieria De Detalle Y Estudios Ambientales (Fase II). The tower is of 14.374 m wide at base and 57.30 m height. The tower was tested for 6 different load cases as per IEC 60 652 standards..

