

Prototype testing of 230 kV Four Circuit, “2Q15” +9 m body extension tower for M/s Power Grid Company of Bangladesh Ltd., Bangladesh

The 230 kV Four Circuit, “2Q15” +9 m body extension tower for **M/s Power Grid Company of Bangladesh Ltd.**, was supplied by **M/s Steel Products Ltd – Kolkata**, through **M/s Aster – HGPT JV**. The four Circuit tower is 9.841 m wide at base and 65.15 m height. The tower was tested for 11 different load cases as per IEC: 60652 2002-06 specifications.

