

Prototype testing of 220 kV D/C TOWER TYPE “DC” (0° - 30°) for LADAKH POWER DEVELOPMENT DEPARTMENT (LPDD) / (GOVERNMENT OF LADAKH).

RECPDCL, (erstwhile REC TRANSMISSION PROJECTS COMPANY LIMITED, GURUGRAM) have referred to **CSIR-Structural Engineering Research Centre, Chennai** for testing of 220 kV D/C TOWER TYPE “DC” (0° - 30°) for **LADAKH POWER DEVELOPMENT DEPARTMENT (LPDD) / (GOVERNMENT OF LADAKH).**

The square based tower is of 14.221 m wide at base and 59.553 m height. The tower was tested for 16 different load cases as per IS 802(Part III)–1978 (Reaffirmed 2003) Standard.

